



DEPARTMENT OF FIRE AND RESCUE SERVICES

	<h1>GENERAL ORDER</h1> 500.03	
---	----------------------------------	---

Originating From	Issue Date	Revision Date	Attachments
Support Services	9/22/2005	8/25/2006	N/A

SUBJECT: Veeder Root Fuel Printouts


APPLICABILITY: All Personnel

POLICY:

Maintaining adequate fuel supplies in station tanks is a critical function. These fuel levels are monitored by various means at different locations. Some of these require the input from Howard County Fire and Rescue Services personnel on a scheduled basis.

- 1 The Veeder Root fuel printouts at Station 9 and 10 are to be checked each weekday, Monday through Friday and then faxed to Central Fleet (x3346).
- 2 An entry shall be made in the station log and initialed by the sender of the fuel readings, noting that the fax has been sent.

Approved:



Joseph A. Herr
Fire Chief